



**Lakefront  
Utility  
Services  
Inc.**

## **BOIL WATER ADVISORY LIFTED FOR RESIDENTS OF CHURCH STREET EAST IN COLBORNE**

August 13, 2018 - Cobourg, ON – The Boil Water Advisory issued on Thursday, August 8, 2018 has been rescinded by the Haliburton Kawartha Pine Ridge District Health Unit. All affected residents have been notified by letter which was delivered this afternoon by staff of Lakefront Utility Services Inc.

On Thursday, August 9, the water main on Church Street East lost pressure when Behan Construction was going to reconnect the water mains at Burnham Street and Church Street East. Staff of Lakefront Utility Services Inc. (LUSI) were on-site for the scheduled tie-in and shut the water main down once the main valve broke as per protocol and to prevent further damage.

As per O Reg 170/03, the Haliburton Kawartha Pine Ridge District Health Unit was contacted immediately regarding the issue and the Health Unit issued the Boil Water Advisory for the affected residents of Church Street East. Once the water main had been repaired and flushed, the HKPR Health Unit requested two sets of water samples to ensure that there was no ecoli or coliform detected, and that chlorine levels are normal. The first sample was collected on August 9<sup>th</sup> at 3:05 p.m. and taken to SGS Canada Inc., and the second sample was collected on August 10<sup>th</sup> at 8:00 a.m. At 2:16 p.m. on Monday, August 13, LUSI received the water samples back from SGS Canada Inc. and forwarded those results along to the HKPR Health Unit, who officially rescinded the Boil Water Advisory at 2:16 p.m.

-30-

For further information please contact;  
Larry Spyrka, Manager of Water Systems  
Lakefront Utility Services Inc.  
207 Division St. Box 577  
Cobourg, ON. K9A 4L3  
905-372-2193 ext.5238